

Veterans Recovery Corps – Home Modification Assessment

Veteran Information

Name: _____

Address: _____

Assessment Date: _____

Assessor: _____

1. Exterior & Entryways

General Access

- ☐ Level pathway to entrance
- ☐ Pathway free of cracks, gaps, or tripping hazards
- ☐ Adequate lighting along walkway
- ☐ Handrails present where needed

Entrance

- ☐ Step-free entry OR ramp installed
- ☐ Ramp slope $\leq 1:12$
- ☐ Ramp has handrails on both sides
- ☐ Landing area at top of ramp (minimum 60" x 60")
- ☐ Door threshold $\leq \frac{1}{2}$ inch

Doorway

- ☐ Minimum doorway width 32"
- ☐ Lever-style door handles
- ☐ Peephole or camera at accessible height

Notes

2. Interior Mobility

Hallways

- ☐ Minimum hallway width 36"
- ☐ Free of clutter and obstacles
- ☐ Adequate lighting

Flooring

- ☐ Non-slip flooring
- ☐ No loose rugs
- ☐ Smooth transitions between rooms

Turning Radius

- ☐ 60" turning radius available in key areas
- ☐ Furniture arranged to allow wheelchair movement

Notes

3. Living Room & Common Areas

Access

- ☐ Clear pathways
- ☐ Accessible seating options
- ☐ Light switches reachable (≤ 48 " height)

Safety

- ☐ No exposed cords
- ☐ Stable furniture
- ☐ Adequate lighting

Notes

4. Kitchen Accessibility

Counters & Cabinets

- ☐ Counter height appropriate
- ☐ Lowered or pull-down cabinets
- ☐ Easy-grip handles

Appliances

- ☐ Side-opening oven
- ☐ Front-control stove
- ☐ Accessible refrigerator shelves
- ☐ Microwave at reachable height

Sink

- ☐ Knee clearance under sink
- ☐ Lever-style faucet
- ☐ Anti-scald device installed

Notes

5. Bathroom Accessibility

General

- ☐ Doorway width ≥ 32 "
- ☐ Non-slip flooring
- ☐ Grab bars installed

Shower

- ☐ Roll-in shower
- ☐ Shower seat
- ☐ Handheld showerhead
- ☐ Anti-scald device

Toilet

- ☐ Raised toilet seat

☐ Grab bars on both sides

☐ Adequate transfer space

Sink

☐ Knee clearance

☐ Lever faucet

☐ Mirror at accessible height

Notes

6. Bedroom Accessibility

Access

☐ Clear pathways around bed

☐ Bed height appropriate for transfers

☐ Closet accessible (lower rods/shelves)

Safety

☐ Adequate lighting

☐ No tripping hazards

Notes

7. Laundry & Utility Areas

☐ Front-loading washer/dryer

☐ Controls reachable

☐ Clear floor space

☐ Adequate lighting

Notes

8. Emergency & Safety Features

☐ Smoke detectors

☐ CO detectors

☐ Fire extinguisher accessible

☐ Emergency exit plan posted

☐ Medical alert system available

Notes

9. Priority Recommendations

High Priority (Safety / Mobility)

☐ _____

☐ _____

Medium Priority (Comfort / Independence)

☐ _____

☐ _____

Low Priority (Convenience / Future Planning)

☐ _____

☐ _____

10. Final Assessment Summary

Overall Accessibility Rating:

☐ Excellent

☐ Good

☐ Needs Improvement

☐ Critical

Assessor Comments: